

**Annexure-VII- Performance Report regarding Reliability Indices**  
**Format for Quarterly Return to be submitted to the Commission by the NIDAR Utilities Panvel LLP**

**(1) System Average Interruption Duration Index (SAIDI)**

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri= Restoration time for each interruption event on ith feeder	Nt=Total number of consumers of the distribution Licensees area	Sum (Ri*Ni) for all feeders excluding agri. Feeders)	SAIDI = 6/5 (in Min)
(1).	(2).	(3).	(4).	(5).	(6).	(7).
1	Oct-22	0	0	1491	0	0
2	Nov-22	0	0	1624	0	0
3	Dec-22	548	18	1746	9864	6
	Total	548	18	1746	9864	6

**(2) System Average Interruption Frequency Index (SAIFI)**

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions=Sum Ni	Nt=Total number of consumers of the distribution Licensees area	SAIFI = (4)/(5)
(1).	(2).	(3).	(4).	(5).	(6).
1	Oct-22	0	0	1491	0.00
2	Nov-22	0	0	1624	0.00
3	Dec-22	548	548	1746	0.31
	Total	548	548	1746	0.31

**(3) Customer Average Interruption Duration Index (CAIDI)**

Sr. No.	Month	SAIDI	SAIFI	SAIDI / SAIFI
(1).	(2).	(3).	(4).	(5).
1	Jul-22	0.00	0.00	0.00
2	Aug-22	0.00	0.00	0.00
3	Sep-22	5.65	0.31	18.00
	Total	5.65	0.31	18.00

**(4) Customer Average Interruption Duration Index (CAIDI) for HT Consumers**

Sr. No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri= Restoration time for each interruption event of HT Consumers	Sum. (Ri*Ni) for all HT Consumers	CAIDI = (5)/(3)
(1).	(2).	(3).	(4).	(5).	(6).
1	Oct-22	0.00	0.00	0.00	0.00
2	Nov-22	0.00	0.00	0.00	0.00
3	Dec-22	1.00	18.00	18.00	18.00
	Total	1.00	18.00	18.00	18.00

*(Signature)*  
03/01/2023